

ADDENDUM 1


iB 02_25_26 – WOOL CREEK P.I.P. REPLACEMENT

MARCH 18, 2026

This addendum is issued as part of the bid documents for the referenced project and serves to amend, clarify, or otherwise modify the original project specifications as outlined below.

Bidders are required to acknowledge receipt of this addendum in their bid submission. Failure to acknowledge this addendum may result in disqualification of the bid.

Answers to Questions received by Wednesday, March 17, 2026.

No.	Question	Response
001	What is the depth of the existing PIP?	Existing is 2.5" – 3". Thickness Depth varies throughout.
002	Could you please provide the critical fall height of the playground equipment? This would be the tallest deck height of the existing playground structures currently on site.	Tallest deck height of existing playground is (~64").
003	Is access the project site through the side gate adjacent to the playground? Please confirm whether access through this gate is approved, restricted, or requires escort/coordination with site staff.	Side gate (adjacent to playground) may be utilized. Coordination will with staff will only be required until temp fencing is in place. See below. 
004	Please confirm if the parking lot area is approved for staging and dumpster placement, or if an alternate location is required.	Parking/staging area will be finalized during preconstruction meeting.
005	Is all scope of work to be completed after business hours and weekends?	Set up and mobilization may be completed during standard operational hours if noise is minimal and staff/student interaction can be avoided.
006	On Attachment 4.1/04, Item 6 – What is the desired thickness of PIP throughout playground?	Thickness to be in accordance with ASTM F1292. Contractor to ensure a flush/smooth transition to all perimeter borders.

-END OF DOCUMENT-