

ADDENDUM #2

June 5, 2026

BID# iB01-26-27

SCCOE CLASSROOM FLOORING

FOR

SANTA CLARA COUNTY OFFICE OF EDUCATION

This Addendum forms a part of the Bid Documents for above project and modifies the original project specifications as noted below. Please acknowledge receipt of this Addendum in your Quote. Failure to do so may subject your response to disqualification.

**Part 1 – Response to Questions:**

1) Question: Underlayment thickness?

Response: Refer to Exhibit A, Section 2.1. Underlayment may vary in thickness from site to site.

Finished flooring surfaces shall meet the following requirements:

- Maximum slope of 0.5% in any direction when measured over a 4-foot span
- Smooth, uniform surface free of abrupt transitions, ridges, or depressions
- No uncontrolled or progressive rolling of an unoccupied wheelchair.

**Part 2 – FLOORING MATERIAL**

The flooring specification is revised as follows:

Vinyl Composition Tile (VCT) is hereby removed from the project requirements previously identified in Exhibit A, Section 2.1 – General Scope.

Provide Mohawk Group “Hot and Heavy II – Secoya 5.0” Luxury Vinyl Tile (LVT), Product C2104.

Refer to the attached Mohawk Group product specification sheet for detailed product characteristics and requirements. Color selection will be provided by Owner in conjunction with Notice of Award.

Installation shall be full spread, glue-down in accordance with manufacturer’s written requirements.

Substitutions will not be accepted.

Bidders shall base their proposal solely on the specified Mohawk Group product. Failure to do so may result in the bid being deemed non-responsive.

### **Part 3 – WALL BASE**

Wall base is included as part of the Work under “Installation of new flooring and base.”

Contractor shall remove and dispose of existing wall base and provide new wall base at all locations where flooring is replaced.

Contractor shall provide minor, incidental patching related to base work.

Wall base shall match existing conditions and shall consist of 6-inch rubber wall base.

Color shall be selected by Owner at time of Notice of Award.

Install wall base in accordance with manufacturer’s recommendations using appropriate adhesive for a complete installation. Wall base shall be continuous and neatly terminated at all corners, edges, and doorways.

### **Part 4 – TRANSITIONS**

Provide and install all required transitions at doorways and between differing floor finishes. Transitions shall be flush and ADA-compliant.

-END OF DOCUMENT-

**HOT AND HEAVY II**

Secoya 5.0 C2104

9.84 in x 59.06 in LVT



<b>Collection</b>	Hot and Heavy II
<b>Style</b>	Secoya 5.0 (C2104)
<b>Product Type</b>	LVT
<b>Size</b>	9.84 in x 59.06 in
<b>Construction</b>	Flexible LVT
<b>Gauge</b>	5 mm
<b>Total Thickness</b>	5 mm
<b>Wear Layer</b>	20 mil (0.5 mm)
<b>Finish</b>	M-Force™ Ultra
<b>Edge Profile</b>	Beveled
<b>Installation</b>	Loose Lay
<b>Installation Method</b>	Monolithic, Brick Ashlar, Vertical Ashlar, Random
<b>Recommended Adhesive</b>	M95.0, M99, MS160, M700 Plus, or Total Bond Adhesive

**Recommended Installation Methods**



Brick Ashlar



Monolithic



Random

**Colorways**



**Caramel Oak**  
Color: 142



**Knotty Oak**  
Color: 148



**Pure Maple**  
Color: 717



**Frosted Oak**  
Color: 727



**Phantom Oak**  
Color: 738



**Sandy Oak**  
Color: 818



**Chai Oak**  
Color: 821



**Honey Maple**  
Color: 828



**Toffee Oak**  
Color: 838



**Amber Maple**  
Color: 842



**Hazelnut Oak**  
Color: 848



**Stable Oak**  
Color: 868



**Toasted Oak**  
Color: 872



**Chimney Oak**  
Color: 917



**Storm Oak**  
Color: 928



**Mystic Oak**  
Color: 936



**Rustic Oak**  
Color: 939

## Testing

<b>Squareness</b>	(ASTM F2421) Passes
<b>Size and Tolerance</b>	(ASTM F2421) Passes
<b>Thickness</b>	(ASTM F386) Passes
<b>Flexibility</b>	(ASTM F137) Passes
<b>Dimensional Stability</b>	(ASTM F2199) Passes
<b>Static Load Limit</b>	(ASTM F970) 1000 psi
<b>Lightfastness</b>	(ASTM F1515) Passes
<b>Residual Indentation</b>	(ASTM F1914) Passes
<b>Resistance to Chemicals</b>	(ASTM F925) Passes
<b>Resistance to Light</b>	(ASTM F1515) Passes
<b>Resistance to Heat</b>	(ASTM F1514) Passes
<b>Radiant Flux</b>	(ASTM E648) Class 1
<b>Smoke Density</b>	(ASTM E662) = 450
<b>Slip Resistance</b>	NFSI B101.1/B101.3 Slip Resistant Certified
<b>Wear Layer Thickness</b>	20 mil (0.5 mm)
<b>Light Reflectancy</b>	19

## Sustainability

<b>Embodied Carbon</b>	11.6 kg CO <sub>2</sub> e/m <sup>2</sup>
<b>Beyond Carbon Neutral</b>	-0.58 kg CO <sub>2</sub> e/m <sup>2</sup>
<b>Mindful Materials</b>	Achiever

---

## Packaging

---

Square Feet Per Carton	24.22
Pieces Per Carton	6
Cartons Per Pallet	68

---

## Warranties

---

[Limited 20 Year M-Force Ultra Commercial Warranty](#)