

ADDENDUM #3

September 2, 2026

BID# iB 02 26 27

CHRISTOPHER RANCH PLAYGROUND TURF

FOR

SANTA CLARA COUNTY OFFICE OF EDUCATION

This Addendum forms a part of the Bid Documents for above project and modifies the original project specifications as noted below. Please acknowledge receipt of this Addendum in your Quote. Failure to do so may subject your response to disqualification.

Part #1: Responses to Questions received after Mandatory Jobwalk, prior to August 31, 2026:

Question	Response
1. Can you allow a C61/D12 license as a sufficient classification for this project? By not allowing this classification you are eliminating contractors who specialize specifically in this scope of work. This classification allows for the entire scope of the project, including base work.	Reference Addendum #2, RFI Response No. 1.
2. Can you specify a specific product for both the turf and pad, preferably a product made in the USA? This way all contractors can supply a bid with all the same parameters.	TigerTurf Diamond Pro is the basis of design. Approved equal products meeting all specified performance requirements may be submitted for review.
3. Are there any requirements for Temporary Fencing installed for the duration of the project?	Temporary Fencing must be low profile. The maximum allowable clearance between the ground and bottom of fence line is 4".

-END OF DOCUMENT-