

ADDENDUM #1

DECEMBER 27, 2023
 IQ 16-23-24 – HOLLISTER DUTCH DOORS
 SANTA CLARA COUNTY OFFICE OF EDUCATION

This Addendum forms a part of the Bid Documents for above project and modifies the original project specifications as noted below. Please acknowledge receipt of this Addendum in your bid form. Failure to do so may subject your response to disqualification.

Project Questions & Responses

December 27, 2023

Project: Hollister Dutch Doors
 Location: Hollister
 Address: 1011 Line Street Hollister Ca. 95023

No.	Location	Question	Response
001	Restrooms 1&2	Are we using hollow metal door frames or wood frames?	We are using metal door frames.
002	Restrooms 1&2	Are we matching a door or are we using paint grade metal or wood doors?	We are using Wooden doors.
003	Restrooms 1&2	What thickness is the door?	Door thickness 1-5/8"
004	Restrooms 1&2	Will it have a shelf?	No shelf needed
005	Restrooms 1&2	Can you provide a brand and model number for the door handles?	Door handles will be provided
END of DOCUMENT			

++ END OF ADDENDUM ONE ++